



Laurel Mountain Midstream, LLC
Park Place 2
2000 Commerce Drive
Pittsburgh, PA 15275
(412) 787-7300
(412) 787-6006 fax

December 20, 2013

Mark Gorog, P.E.
Environmental Engineer Manager
Air Quality Program
Pennsylvania Department of Environmental Protection
Southwest Regional Office
400 Waterfront Drive
Pittsburgh, PA 15222-4745

Subject: Springhill Compressor Station
GP5-26-00587B
Springhill Township, Fayette County, PA

Dear Mr. Gorog:

Per your request, Laurel Mountain Midstream Operating LLC (LMM) reviewed operations at its Springhill Compressor Station in Springhill Township, Fayette County (the "Facility"). Dick Baker, Lindsay Sumpter and I reviewed the operations at the Facility November 11, 2013, including a review of each potential source of odor.

The group walked around the surrounding area and found no odors outside the fenceline. However, an acrid odor accumulation was noticeable within the fenceline. The odor appears to be coming from the produced water tank attached to the dehydrator. The vent on this tank is below the roofline of the surrounding compressor buildings. The vent's location is resulting in an accumulation and concentration of odor around the tank at ground level.

LMM proposes the following measures in an effort to remedy the odor concerns:

1. LMM Environmental Specialists reviewed aspects of current odor monitoring program with operation technicians and supervisors. In addition to the present monitoring program, LMM technicians will drive

Mark Gorog, P.E.
Southwest Regional Office - PADEP
December 20, 2013
Page 2 of 2

- through surrounding neighborhoods with their windows down when leaving the Facility. (Ongoing)
2. LMM will evaluate raising the elevation of the tank vent above the roofline of the surrounding buildings as a potential means of alleviating the accumulation and concentration of odor at ground level. The evaluation and changes would be completed by February 28, 2014.
 3. If item 2 does not remedy the concern, LMM will evaluate the applicability of using a flare for control of the odor. LMM will update the department, on feasibility and provide a schedule for installation, if relevant, by June 30, 2014.

Thank you for your attention in this matter. Please contact me at 412-787-4197 or joe.mccay@williams.com if you have any questions.

Sincerely,



Joseph R. McCay
Environmental Specialist

Attachments

CC: Lindsay Sumpter
Dick Baker
Daniel Haefelin
Mark Lezama
Mark Gorog, PADEP